

A perceptable reduction in the electrical line voltage supplied is usually caused by an excessive electrical demand on the electric utility or by an insufficient power-generation capability. This is also known as brown-down.

From:

<http://www.midibox.org/dokuwiki/> - **MIDIbox**

Permanent link:

<http://www.midibox.org/dokuwiki/doku.php?id=dictionary:brownout>

Last update: **2007/11/17 18:38**

